

CO2 Sampling Results - Phase 2

Beechwood	
Date: 11/13/20 and 11/16/20	
Start Time: 1:02pm and 8:35am	
Outdoor CO2(ppm): 452	
Outdoor + 700(ppm): 1152	
Room	CO2 (ppm)
10	610
9	761
6	747
5	530
Gym	498
Kitchen Office	716
Nurse	527
13	726
18	916
19	686
8	530
3	583
1	473
14	533
16	576

ECC	
Date: 11/13/20	
Start Time: 10:00am	
Outdoor CO2(ppm): 460	
Outdoor + 700(ppm): 1160	
Room	CO2 (ppm)
15	735
12	732
13	710
14	620
6	640
5	813
3	640
1	556

Merrymount	
Date: 11/16/20	
Start Time: 11:45am	
Outdoor CO2(ppm): 444	
Outdoor + 700(ppm): 1144	
Room	CO2 (ppm)
32	478
33A	548
34	547
37	486
Media Center	569
38	523
31	500
22	533
23	509
24	518
25	538
26	535
20	583
11	506
12	468
Gym	575
Gym	571

QHS	
Date: 11/12/20	
Start Time: 10:05am	
Outdoor CO2(ppm): 452	
Outdoor + 700(ppm): 1152	
Room	CO2 (ppm)
A401	522
A431	526
A405	512
A424	555
A406	521
A422	502
A409	507
A410	511
A316	537
A308	521
A318	564
A322	575
A307	578
A304	553
A328	524
A206	597
A209	555
A210	563
A232	530
A119	507
A113	480
C310	526
C314	549
C316	540
D333	493
D330	614
D314	506
D312	480
C322	525
C301	505
C304	534
B307	511
B301	512
C201 Library	511
C201 Library	510
C234	499
D217	555
D221	496
D224	502
D208	553
D202	498
Cafeteria	499
B104 Gym	471
B104 Gym	468
C125	511
C135	478
D122	516
D139	488
D102	475
C152	694
Cafeteria	492

18	= 700-800ppm
8	= 800-1100ppm
1	> 1100ppm

Parker	
Date:	11/13/20
Start Time:	11:39am
Outdoor CO2(ppm):	444
Outdoor + 700(ppm):	1144
Room	CO2 (ppm)
Principal Office	552
Nurse	570
6	889
10	649
3	837
1	555
Library	608
17A	659
17	569
19	524
20A	540

Clifford Marshal	
Date:	11/12/20
Start Time:	10:30am
Outdoor CO2(ppm):	471
Outdoor + 700(ppm):	1171
Room	CO2 (ppm)
Reception	650
Nurse	589
Gym	570
112	492
110	628
109	673
108	506
107	639
105	672
103	611
102	655
217	556
216	565
215	634
Music	538
213	546
206	555
207	562
208	551
205	503
203	559
202	567
201	529

Point Webster	
Date:	11/12/20
Start Time:	8:30am
Outdoor CO2(ppm):	470
Outdoor + 700(ppm):	1170
Room	CO2 (ppm)
36	690
38	641
8	538
22/Kitchen	502
25B	614
28A	549
34	538
128	549
126	506
124	556
110	576
1	573
201/Auditorium	519
213	545
219	539
226	549
141 Nurse	536
18 103	559

Central	
Date:	11/12/20
Start Time:	12:36pm
Outdoor CO2(ppm):	453
Outdoor + 700(ppm):	1153
Room	CO2 (ppm)
Reception	518
Nurse	536
122	638
102	628
105A	517
Library	554
225	536
222	549
321	637
301	600
302	622
306	579
315	545
316	576
Gym A	586
Auditorim	501
Custodial	499

NQHS	
Date: 11/16/20	
Start Time: 9:30am	
Outdoor CO2(ppm): 479	
Outdoor + 700(ppm): 1179	
Room	CO2 (ppm)
Café	466
Kitchen	481
Attendance Office	487
101A	550
107	514
208	656
Nurse	483
Main Office	523
242	513
243	610
226	518
226A	521
221/226C	588
220A	635
219	506
316C	520
316D	497
316B	523
316A	521
310 Teachers Rm	502
312	505
311	510
309	483
305	475
304A	462
327	516
328	490
444	667
448	721
414	482

Atlantic	
Date: 11/12/20	
Start Time: 11:50am	
Outdoor CO2(ppm): 443	
Outdoor + 700(ppm): 1143	
Room	CO2 (ppm)
Café	518
Kitchen	559
113	595
111	812
109	526
217	565
212	595
Library	597
201	574
208	547
208	782
Reception	522

Lincoln Hancock	
Date: 11/13/20	
Start Time: 10:50am	
Outdoor CO2(ppm): 450	
Outdoor + 700(ppm): 1150	
Room	CO2 (ppm)
301	510
Library	526
303	506
304	563
306	577
307	583
308	574
309	598
201	482
203	577
211	503
Lobby	499
Gym	510
Gym	509
118	596
131	1075
Office	550

Montclair	
Date: 11/13/20	
Start Time: 12:47pm	
Outdoor CO2(ppm): 437	
Outdoor + 700(ppm): 1137	
Room	CO2 (ppm)
Office	660
204	757
205	528
206	539
211	635
208	555
209	585
210	593
307	641
305	591
304	523
302	584
105	535
107	566
108	552
109	635
Nurse	572

Wollaston	
Date: 11/19/20	
Start Time: 9:30am	
Outdoor CO2(ppm): 487	
Outdoor + 700(ppm): 1187	
Room	CO2 (ppm)
13	495
17	514
10	567
12	515
5	525
3	577
1	568
8	564
7	593
6	573
20	561
19	527

Snug Harbor	
Date: 11/13/20	
Start Time: 9:30am	
Outdoor CO2(ppm): 453	
Outdoor + 700(ppm): 1153	
Room	CO2 (ppm)
Office	612
17	555
18	678
19	565
21	640
1	548
8	555
7	542
Nurse	568
13	636
15	692
9	719
26	498
27	623
25	527
23	508
Library	482

Atherton Hough	
Date: 11/13/20	
Start Time: 8:26am	
Outdoor CO2(ppm): 437	
Outdoor + 700(ppm): 1137	
Room	CO2 (ppm)
1	554
10	590
2	527
8A	567
3	555
4	554
7	551
6	659
5	609
16	566
17	577
18	538
14	541
13/Library	555
12	529
11	560
21	649
22	580
Pyscology Rm 3	1720
OT Rm	588
Gym	519
22 Principal Office	510

Goals	
Date: 11/19/20	
Start Time: 11:00am	
Outdoor CO2(ppm): 490	
Outdoor + 700(ppm): 1190	
Room	CO2 (ppm)
1st	875
2nd	741
3rd	750
4th	557

Broad Meadows	
Date: 11/16/20	
Start Time: 11:00am	
Outdoor CO2(ppm): 439	
Outdoor + 700(ppm): 1139	
Room	CO2 (ppm)
218	499
211	550
205	651
206	729
208	786
212	727
214	635
Library	502
Office	532

Southwest	
Date: 11/13/20	
Start Time: 8:30am	
Outdoor CO2(ppm): 430	
Outdoor + 700(ppm): 1130	
Room	CO2 (ppm)
238	539
238	533
243	500
243	517
244	523
250	529
Cafeteria	534
Cafeteria	522
Cafeteria	519
Cafeteria	518
138	553
138	565
136	539
143	580
143	578
141	677
146	608
41	665
Gym	553
Gym	550
Office 101	505
131	508

Bernazzani	
Date: 11/16/20	
Start Time: 1:06pm	
Outdoor CO2(ppm): 475	
Outdoor + 700(ppm): 1175	
Room	CO2 (ppm)
5	572
4	540
2	539
1	578
14	567
13	607
12	762
Gym	545
18	689
17	695
16	677
10	649
7	796
6	499
Library	523

Squantum	
Date: 11/19/20	
Start Time: 10:15am	
Outdoor CO2(ppm): 515	
Outdoor + 700(ppm): 1215	
Room	CO2 (ppm)
9	473
Library	561
13	665
15	866
Library, enclosed rm	521
18	552
22	617
23	575
24	538
27	569
28	534
30	595
31	562
32	556